



accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

European Notified Body for construction products 0766
Recognized body of DIBt SAC03

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-21-03-05-01

Products: Floorings: "SPC Floor Concept", „SPC Plank“, Top layer: PVC, UV coating, Structure: BP dimensions: length (600-1830) mm x width (125-610) mm x thickness (3.5-7.0) mm

Client: ACARA PRAHA s.r.o.
Tachovské náměstí 90/2
130 00 Praha 3
Czech Republik

Order: Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

Test report: 2708003/199

Test results: *The above mentioned SPC Floorings can be classified regarding to the tested properties according to EN 14041:2008 (CE-labelling) as follows:*

Properties	Results	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1 and EN ISO 11925-2, Classification according to EN 13501-1:2019 - Critical heat flux - Smoke production	11.7 kW / m ² 646 % x min	Reaction to fire class B _{fl} -s1
Sliding behavior according to EN 13893:2003	μ = 0.41	class DS

Dresden, 05/03/2021


Head of laboratory




Engineer in charge



SPC PODLAHY
VINYL NOVÉ GENERACE